



Product Service

CERTIFICATE

No. B 110281 0001 Rev. 01

Holder of Certificate: **Zakłady Kablowe BITNER Sp. z o.o.**
3/3 Józefa Friedleina Street
30-009 Kraków
POLAND

Certification Mark:



Product:

Connector
Connectors for Photovoltaic Systems

Model(s):

ST4, ST5, ST6

Parameters:

Rated Voltage: 1500VDC
Rated Current: 30A for ST4, ST5
15A or 30A for ST6
Application Class A
Protection Class: II
Degree of Protection: IP65/IP68(1m,1h)
Ambient Temperature: -40°C ~ +85°C

Tested according to:

IEC 62852:2014
IEC 62852:2014/AMD1:2020
EN 62852:2015/A1:2020

The product was tested on a voluntary basis and complies with the essential requirements. The certification mark shown above can be affixed on the product. It is not permitted to alter the certification mark in any way. In addition, the certification holder must not transfer the certificate to third parties. This certificate is valid until the listed date, unless it is cancelled earlier. All applicable requirements of the testing and certification regulations of TÜV SÜD Group have to be complied. For details see: www.tuvsud.com/ps-cert

Test report no.: 701262014001-01

Valid until: 2026-04-12

Date, 2021-05-25

(Yaquun Alex Liu)